


FIRE SAFETY CERTIFICATE

Certified that Gyan Mandir Public School located at E-Block, Naraina Vihar, New Delhi- 110028, comprised of basement, ground plus two upper floor, was granted Fire Safety Certificate vide letter No. F.6/DFS/MS/School/SZ/2021/85 dated 02.02.2021. The school building was re-inspected by the officer concerned of this department on 09.01.2024 in the presence of Mr. Khemka Sharma, Facility in charge of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and that the building/premises is fit for occupancy class "Educational" with effect from 15/01/2024 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions printed below under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/01/2024 at New Delhi by.



(Atul Garg)
Director
Delhi Fire Service

Copy to: -

- ✓ The Principal, Gyan Mandir Public School, E-Block, Naraina Vihar, New Delhi- 28.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement used only for storage purpose as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.


RAJESH BANOPREEYA
PRINCIPAL
GYAN MANDIR PUBLIC SCHOOL
E-BLOCK NARAINA VIHAR
NEW DELHI-110028